



ENERGY STAR CERTIFIED

Uninterruptible Power Supplies

CyberPower - BRG1500AVRLCD : BRG1500AVRLCD

Specifications

ENERGY STAR Unique ID:	2331554
Brand Name:	CyberPower
Model Name:	BRG1500AVRLCD
Model Number:	BRG1500AVRLCD
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	BRG1500AVRLCD
Active Output Power Rating Minimum Configuration (W):	900
Apparent Output Power Rating Minimum Configuration (VA):	1500
Topology (ac):	Line Interactive
Topology and Product Type Combined:	ac Line Interactive (VI)
Application:	Commercial,Consumer
Rated Input Voltage (V rms):	120-120
Rated Input Frequency (Hz):	60-60
Rated Output Voltage (V):	120-120
Rated Output Frequency (Hz):	60-60
Rack Mountable:	No
Height (mm):	279
Width (mm):	99
Depth (mm):	356
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage Independent
Modular UPS:	No
Number of Normal Modes:	Single-normal-mode
Default Normal Mode (ac):	Voltage Independent
Test Input Voltage (V rms):	120
Test Input Frequency (Hz):	60
Test Output Voltage (V):	120
Test Output Frequency (Hz):	60
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac):	5.7
Efficiency at 25% Load Min Config Lowest Dependency (ac):	97.4

Efficiency at 50% Load Min Config Lowest Dependency (ac):	98.4
Efficiency at 75% Load Min Config Lowest Dependency (ac):	98.7
Efficiency at 100% Load Min Config Lowest Dependency (ac):	98.7
Weighted Efficiency Calc Min Config Lowest Dependency:	98.6
Efficiency (%):	98.6
Modular UPS Module Tested Model Number:	N/A
Energy Storage Mechanism:	Battery
Energy Storage System Technology:	Valve Regulated Lead-acid Battery
Energy Storage System Configuration:	Integral
Energy Storage System Removable to Another Room:	No
Energy Storage System Runtime at 100% Load (min.):	2
Energy Storage System Runtime at 50% Load (min.):	12
Energy Storage System Warranty (yrs):	3
Energy Storage System Information URL:	N/A
Network Connections Available:	Serial Port,USB Port
Communication Protocols:	Other
Communication Protocol Other:	HID CyberPower serial Protocol (v2)
Manufacturer Take Back Program:	Yes
Model Web Page URL:	https://www.cyberpowersystems.com/product/ups/brg1500avrlcd/
Test Method Guidelines:	N/A
Date Available on Market:	2014-05-15
Date Certified:	2018-12-17
Markets:	United States, Canada
ENERGY STAR Certified:	Yes

Additional Model Information

BRG1350AVRLCD,BRG1350AVRLCD;; BRG1350AVRLCDTAA,BRG1350AVRLCDTAA;; BRG1500AVRLCDTAA,BRG1500AVRLCDTAA,

Captured On:
04/29/2025