

## EXR Series - EXR750RT2U: 90000965

Specifications	
ENERGY STAR Unique ID:	2370405
Brand Name:	EXR Series
Model Name:	EXR750RT2U
Model Number:	90000965
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	EXR750RT2UNC
Active Output Power Rating Minimum Configuration (W):	675
Apparent Output Power Rating Minimum Configuration (VA):	750
Maximum Configuration Tested Model Number:	N/A
Topology (ac):	Passive Standby
Topology and Product Type Combined:	Alternating Current (ac) - Offline (VFD)
Application:	Consumer,Commercial
Rated Input Voltage (V rms):	78-164
Rated Input Frequency (Hz):	44-66
Rated Output Voltage (V):	97-141
Rated Output Frequency (Hz):	44-66
Rack Mountable:	Yes
Rack Mount Height (U):	2
Height (mm):	89
Width (mm):	556
Depth (mm):	482
Total Number of Outlets:	8
Number of Battery Backup and Surge Protected Outlets:	8
Number of Surge Protected Only Outlets:	0
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage and Frequency Dependent
Modular UPS:	Yes
Number of Normal Modes:	Single-normal-mode
Default Normal Mode (ac):	Voltage and Frequency Dependent
Test Input Voltage (V rms):	120

Test Input Frequency (Hz): 60	
700 mpat 1 oquesio, (1.2).	
Test Output Voltage (V): 120	
Test Output Frequency (Hz): 60	
Total Input Power in W at 0% Load Min Config 6.04 Lowest Dependency (ac):	
Efficiency at 25% Load Min Config Lowest Dependency (ac):  96.2	
Efficiency at 50% Load Min Config Lowest Dependency (ac):  98.0	
Efficiency at 75% Load Min Config Lowest Dependency (ac):  98.4	
Efficiency at 100% Load Min Config Lowest Dependency (ac):  98.5	
Weighted Efficiency Calc Min Config Lowest Dependency:  98.4	
<b>Efficiency (%):</b> 98.4	
Modular UPS Module Tested Model Number: N/A	
Energy Storage Mechanism: Other	
Energy Storage System Technology: Other	
Energy Storage System Configuration: Integral	
Energy Storage System Removable to Another Yes Room:	
Energy Storage System Runtime at 100% Load 9 (min.):	
Energy Storage System Runtime at 50% Load (min.):	
Energy Storage System Warranty (yrs): 3	
Energy Storage System Information URL: N/A	
Network Connections Available: Serial Port,Other,USB Port,Ethernet	
Communication Protocols: HTTP,Other,SNMP (v1, 2 or 3)	
Communication Protocol Other: USB: HID power device protocol; Serial: Other	
Manufacturer Take Back Program: Yes	
Model Web Page URL: https://minutemanups.com/	
Test Method Guidelines: N/A	
Date Available on Market: 2021-01-01	
Date Certified: 2020-12-01	
Date Certified:2020-12-01Markets:United States, Taiwan, Japan, Canada	

**Captured On:** 04/28/2025