

APC by Schneider Electric - APC Smart-UPS Lithium-Ion 3000VA 120VAPC Smart-UPS Lithium-Ion 3000VA 120V with SmartConnect Port and Network Card : SMTL3000RM2UCNC

Specifications	
ENERGY STAR Unique ID:	2383920
Brand Name:	APC by Schneider Electric
Model Name:	APC Smart-UPS Lithium-Ion 3000VA 120VAPC Smart-UPS Lithium-Ion 3000VA 120V with SmartConnect Port and Network Card
Model Number:	SMTL3000RM2UCNC
Power Conversion Mechanism:	Static
Minimum Configuration Tested Model Number:	SMTL3000RM2UC
Active Output Power Rating Minimum Configuration (W):	2700
Apparent Output Power Rating Minimum Configuration (VA):	2880
Maximum Configuration Tested Model Number:	SMTL3000RM2UC
Topology (ac):	Line Interactive
Topology and Product Type Combined:	ac Line Interactive (VI)
Application:	Commercial
Rated Input Voltage (V rms):	110-125
Rated Input Frequency (Hz):	50-60
Rated Output Voltage (V):	110-125
Rated Output Frequency (Hz):	50-50
Rack Mountable:	Yes
Rack Mount Height (U):	2
Height (mm):	86
Width (mm):	432
Depth (mm):	683
Total Number of Outlets:	8
Number of Battery Backup and Surge Protected Outlets:	8
Number of Surge Protected Only Outlets:	0
Normal Mode(s) Input Dependency Characteristic (ac):	Voltage Independent

Modular UPS: No Number of Normal Modes: Single-normal-mode Default Normal Mode (ac): Voltage Independent Test Input Voltage (V rms): 120 Test Input Frequency (Hz): 60 Test Output Voltage (V): 120 Test Output Frequency (Hz): 60 Total Input Power in W at 0% Load Min Config 5.3 Lowest Dependency (ac): 98.9 Efficiency at 25% Load Min Config Lowest Dependency (ac): 98.9 Efficiency at 50% Load Min Config Lowest Dependency (ac): 98.6 Efficiency at 70% Load Min Config Lowest Dependency (ac): 98.6 Efficiency at 100% Load Min Config Lowest Dependency (ac): 98.6 Weighted Efficiency Calc Min Config Lowest Dependency: 98.6 Weighted Efficiency Calc Min Config Lowest Dependency: 98.6 Befficiency (%): 98.6 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Lithium-ion Battery Energy Storage System Removable to Another Room: No Energy Storage System Runtime at 100% Load 4 </th
Default Normal Mode (ac): Voltage Independent Test Input Voltage (V rms): 120 Test Input Frequency (Hz): 60 Test Output Voltage (V): 120 Test Output Frequency (Hz): 60 Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): 5.3 Efficiency at 25% Load Min Config Lowest Dependency (ac): 98.9 Efficiency at 50% Load Min Config Lowest Dependency (ac): 98.6 Dependency (ac): 98.6 Efficiency at 75% Load Min Config Lowest Dependency (ac): 98.6 Efficiency at 100% Load Min Config Lowest Dependency (ac): 98.6 Modular UPS Module Tested Model Number: N/A Energy Storage System Technology: Lithium-ion Battery Energy Storage System Removable to Another Room:
Test Input Voltage (V rms): 120 Test Input Frequency (Hz): 120 Test Output Voltage (V): 120 Test Output Frequency (Hz): 60 Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): 98.9 Efficiency at 25% Load Min Config Lowest Dependency (ac): 98.9 Efficiency at 50% Load Min Config Lowest Dependency (ac): 98.6 Efficiency at 75% Load Min Config Lowest Dependency (ac): 98.6 Efficiency at 100% Load Min Config Lowest Dependency (ac): 98.6 Efficiency at 100% Load Min Config Lowest Dependency (ac): 98.6 Meighted Efficiency Calc Min Config Lowest Dependency (ac): 98.6 Modular UPS Module Tested Model Number: N/A Energy Storage System Technology: Lithium-ion Battery Energy Storage System Removable to Another Room:
Test Input Frequency (Hz): 120 Test Output Voltage (V): 120 Test Output Frequency (Hz): 60 Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): 98.9 Efficiency at 25% Load Min Config Lowest Dependency (ac): 98.9 Efficiency at 50% Load Min Config Lowest Dependency (ac): 98.6 Efficiency at 75% Load Min Config Lowest Dependency (ac): 98.6 Efficiency at 100% Load Min Config Lowest Dependency (ac): 98.6 Efficiency at 100% Load Min Config Lowest Dependency (ac): 98.6 Meighted Efficiency Calc Min Config Lowest Dependency: 98.6 Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Lithium-ion Battery Energy Storage System Removable to Another Room:
Test Output Voltage (V): Test Output Frequency (Hz): Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): Efficiency at 25% Load Min Config Lowest Dependency (ac): Efficiency at 50% Load Min Config Lowest Dependency (ac): Efficiency at 75% Load Min Config Lowest Dependency (ac): Efficiency at 75% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Weighted Efficiency Calc Min Config Lowest Dependency: Efficiency (%): Modular UPS Module Tested Model Number: Energy Storage Mechanism: Energy Storage System Technology: Eithium-ion Battery Energy Storage System Removable to Another Room:
Test Output Frequency (Hz): Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): Efficiency at 25% Load Min Config Lowest Dependency (ac): Efficiency at 50% Load Min Config Lowest Dependency (ac): Efficiency at 75% Load Min Config Lowest Dependency (ac): Efficiency at 75% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Weighted Efficiency Calc Min Config Lowest Dependency: Efficiency (%): Modular UPS Module Tested Model Number: Energy Storage Mechanism: Energy Storage System Technology: Eintium-ion Battery Energy Storage System Removable to Another Room:
Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): Efficiency at 25% Load Min Config Lowest Dependency (ac): Efficiency at 50% Load Min Config Lowest Dependency (ac): Efficiency at 50% Load Min Config Lowest Dependency (ac): Efficiency at 75% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Weighted Efficiency Calc Min Config Lowest Dependency: Efficiency (%): Modular UPS Module Tested Model Number: Energy Storage Mechanism: Energy Storage System Technology: Eithium-ion Battery Energy Storage System Configuration: Energy Storage System Removable to Another Room:
Lowest Dependency (ac): Efficiency at 25% Load Min Config Lowest Dependency (ac): Efficiency at 50% Load Min Config Lowest Dependency (ac): Efficiency at 75% Load Min Config Lowest Dependency (ac): Efficiency at 175% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Weighted Efficiency Calc Min Config Lowest Dependency: Efficiency (%): Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Lithium-ion Battery Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room:
Dependency (ac): Efficiency at 50% Load Min Config Lowest Dependency (ac): Efficiency at 75% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Weighted Efficiency Calc Min Config Lowest Dependency: Efficiency (%): Modular UPS Module Tested Model Number: Energy Storage Mechanism: Energy Storage System Technology: Energy Storage System Configuration: Energy Storage System Removable to Another Room:
Dependency (ac): Efficiency at 75% Load Min Config Lowest Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Weighted Efficiency Calc Min Config Lowest Dependency: Efficiency (%): Modular UPS Module Tested Model Number: Energy Storage Mechanism: Energy Storage System Technology: Einergy Storage System Configuration: Energy Storage System Removable to Another Room:
Dependency (ac): Efficiency at 100% Load Min Config Lowest Dependency (ac): Weighted Efficiency Calc Min Config Lowest Dependency: Efficiency (%): Modular UPS Module Tested Model Number: Energy Storage Mechanism: Energy Storage System Technology: Energy Storage System Configuration: Energy Storage System Removable to Another Room: No
Dependency (ac): Weighted Efficiency Calc Min Config Lowest Dependency: Efficiency (%): Modular UPS Module Tested Model Number: Energy Storage Mechanism: Energy Storage System Technology: Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room:
Dependency: Efficiency (%): Modular UPS Module Tested Model Number: Energy Storage Mechanism: Energy Storage System Technology: Lithium-ion Battery Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room:
Modular UPS Module Tested Model Number: N/A Energy Storage Mechanism: Battery Energy Storage System Technology: Lithium-ion Battery Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room:
Energy Storage Mechanism: Energy Storage System Technology: Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room: No
Energy Storage System Technology: Lithium-ion Battery Integral Energy Storage System Removable to Another Room: Lithium-ion Battery Integral
Energy Storage System Configuration: Integral Energy Storage System Removable to Another Room:
Energy Storage System Removable to Another No Room:
Room:
Energy Storage System Runtime at 100% Load 4
(min.):
Energy Storage System Runtime at 50% Load 8 (min.):
Energy Storage System Warranty (yrs): 5
Energy Storage System Information URL: https://www.apc.com/shop/us/en/products/P-APCRBC174-LI
Battery Recycling URL: https://www.apc.com/us/en/who-we-are/sustainability/recycling-options.jsp
Network Connections Available: Serial Port,USB Port,Ethernet
Communication Protocols: HTTP,HTTPS,Other,Modbus TCP,SNMP (v1, 2 or 3),Modbus RTU
Communication Protocol Other: USB Power Summary, Micro-Link, Simple Signaling, SmartConnect
Manufacturer Take Back Program: Yes
Manufacturer Take Back Program URL: https://www.apc.com/us/en/who-we-are/sustainability/recycling-options.jsp
Model Web Page URL: https://www.apc.com/shop/us/en/products/P-SMTL3000RM2UCNC
Test Method Guidelines: https://www.apc.com/us/en/who-we-are/sustainability/
Date Available on Market: 2021-06-10
Date Certified: 2021-08-27
Markets: United States, Canada
ENERGY STAR Certified: Yes

Additional Model Information

APC Smart-UPS Lithium-Ion 3000VA 120V with SmartConnect Port and Network Card Factory Serviced,SMTL3000RM2UCNCW,; Std Exch APC Smart-UPS Lithium-Ion 3000VA 120V with SmartConnect Port and Network Card,SMTL3000RM2UCNCQ,

UPC Codes 731304429104

Captured On: 04/25/2025