



ENERGY STAR CERTIFIED

Uninterruptible Power Supplies

Minuteman - EXR3000RTHV : EXR3000RTHV

Specifications

| | |
|--|--------------------------|
| ENERGY STAR Unique ID: | 2390354 |
| Brand Name: | Minuteman |
| Model Name: | EXR3000RTHV |
| Model Number: | EXR3000RTHV |
| Power Conversion Mechanism: | Static |
| Minimum Configuration Tested Model Number: | EXR3000RTHV |
| Active Output Power Rating Minimum Configuration (W): | 2700 |
| Apparent Output Power Rating Minimum Configuration (VA): | 3000 |
| Topology (ac): | Line Interactive |
| Topology and Product Type Combined: | ac Line Interactive (VI) |
| Application: | Consumer |
| Rated Input Voltage (V rms): | 208-240 |
| Rated Input Frequency (Hz): | 50-60 |
| Rated Output Voltage (V): | 208-240 |
| Rated Output Frequency (Hz): | 50-60 |
| Rack Mountable: | Yes |
| Rack Mount Height (U): | 2 |
| Height (mm): | 89 |
| Width (mm): | 482 |
| Depth (mm): | 600 |
| Total Number of Outlets: | 7 |
| Number of Battery Backup and Surge Protected Outlets: | 7 |
| Number of Surge Protected Only Outlets: | 0 |
| Normal Mode(s) Input Dependency Characteristic (ac): | Voltage Independent |
| Modular UPS: | No |
| Number of Normal Modes: | Single-normal-mode |
| Default Normal Mode (ac): | Voltage Independent |
| Test Input Voltage (V rms): | 240 |
| Test Input Frequency (Hz): | 60 |
| Test Output Voltage (V): | 240 |

| | |
|---|---|
| Test Output Frequency (Hz): | 60 |
| Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): | 7.8 |
| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 98.7 |
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 99.1 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 99.2 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 99.1 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 99.1 |
| Efficiency (%): | 99.1 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Battery |
| Energy Storage System Technology: | Valve Regulated Lead-acid Battery |
| Energy Storage System Configuration: | Integral |
| Energy Storage System Removable to Another Room: | No |
| Energy Storage System Runtime at 100% Load (min.): | 3 |
| Energy Storage System Runtime at 50% Load (min.): | 10 |
| Energy Storage System Warranty (yrs): | 3 |
| Energy Storage System Information URL: | N/A |
| Network Connections Available: | None |
| Communication Protocols: | None |
| Manufacturer Take Back Program: | Yes |
| Manufacturer Take Back Program URL: | https://minutemanups.com/download-manuals/#1580312877669-7a202af3-5231 |
| Model Web Page URL: | https://minutemanups.com/uninterruptible-power-supply/exr-series-line-interactive-uninterruptible-power-supply/ |
| Test Method Guidelines: | N/A |
| Date Available on Market: | 2022-05-01 |
| Date Certified: | 2022-01-05 |
| Markets: | United States, Canada |
| ENERGY STAR Certified: | Yes |

Captured On:
05/19/2025