



ENERGY STAR CERTIFIED

Uninterruptible Power Supplies

CyberPower - CP1000PFCRM1U : CP1000PFCRM1U

Specifications

| | |
|--|-----------------------------------|
| ENERGY STAR Unique ID: | 3360697 |
| Brand Name: | CyberPower |
| Model Name: | CP1000PFCRM1U |
| Model Number: | CP1000PFCRM1U |
| Power Conversion Mechanism: | Static |
| Minimum Configuration Tested Model Number: | CP1000PFCRM1U |
| Active Output Power Rating Minimum Configuration (W): | 600 |
| Apparent Output Power Rating Minimum Configuration (VA): | 1000 |
| Topology (ac): | Line Interactive |
| Topology and Product Type Combined: | ac Line Interactive (VI) |
| Application: | Data Center,Consumer,Commercial |
| Rated Input Voltage (V rms): | 120-120 |
| Rated Input Frequency (Hz): | 60-60 |
| Rated Output Voltage (V): | 120-120 |
| Rated Output Frequency (Hz): | 60-60 |
| Rack Mountable: | Yes |
| Rack Mount Height (U): | 1 |
| Height (mm): | 44 |
| Width (mm): | 433 |
| Depth (mm): | 389 |
| Total Number of Outlets: | 6 |
| Number of Battery Backup and Surge Protected Outlets: | 4 |
| Number of Surge Protected Only Outlets: | 2 |
| Normal Mode(s) Input Dependency Characteristic (ac): | Voltage and Frequency Independent |
| Modular UPS: | No |
| Number of Normal Modes: | Single-normal-mode |
| Default Normal Mode (ac): | Voltage and Frequency Independent |
| Test Input Voltage (V rms): | 120 |
| Test Input Frequency (Hz): | 60 |
| Test Output Voltage (V): | 120 |

| | |
|--|---|
| Test Output Frequency (Hz): | 60 |
| Total Input Power in W at 0% Load Min Config Lowest Dependency (ac): | 3.31 |
| Efficiency at 25% Load Min Config Lowest Dependency (ac): | 97.3 |
| Efficiency at 50% Load Min Config Lowest Dependency (ac): | 98.5 |
| Efficiency at 75% Load Min Config Lowest Dependency (ac): | 98.6 |
| Efficiency at 100% Load Min Config Lowest Dependency (ac): | 98.6 |
| Weighted Efficiency Calc Min Config Lowest Dependency: | 98.6 |
| Efficiency (%): | 98.6 |
| Modular UPS Module Tested Model Number: | N/A |
| Energy Storage Mechanism: | Battery |
| Energy Storage System Technology: | Valve Regulated Lead-acid Battery |
| Energy Storage System Configuration: | Integral |
| Energy Storage System Removable to Another Room: | No |
| Energy Storage System Runtime at 100% Load (min.): | 2 |
| Energy Storage System Runtime at 50% Load (min.): | 11 |
| Energy Storage System Warranty (yrs): | 3 |
| Energy Storage System Information URL: | https://www.cyberpowersystems.com/ |
| Battery Recycling URL: | https://www.cyberpowersystems.com/faqs/what-should-i-do-with-spent-batteries/ |
| Network Connections Available: | Serial Port,Ethernet |
| Communication Protocols: | HTTP,HTTPS,SNMP (v1, 2 or 3) |
| Manufacturer Take Back Program: | Yes |
| Manufacturer Take Back Program URL: | https://www.cyberpowersystems.com/faqs/how-do-i-dispose-of-my-ups/ |
| Model Web Page URL: | http://www.cyberpowersystems.com/ |
| Test Method Guidelines: | https://www.cyberpowersystems.com/ |
| Date Available on Market: | 2024-05-15 |
| Date Certified: | 2024-01-11 |
| Markets: | United States |
| ENERGY STAR Certified: | Yes |

Additional Model Information

CP1200PFCRM1U,CP1200PFCRM1U,, CP1500PFCRM1U,CP1500PFCRM1U,

| | |
|-----------|--------------|
| UPC Codes | 649532936854 |
|-----------|--------------|

Captured On:
04/29/2025